


LEGEND				LEGEND			
SYMBOL		DESCRIPTION		SYMBOL		DESCRIPTION	
	DISCONNECTOR		AUXILIARY RELAY		ANTI PUMPING RELAY		TRIP-NEUTRAL-CLOSE SWITCH
	MOTORISED DRAW-OUT TYPE CIRCUIT BREAKER (Type V, S or A, SFS, SFC, A-ACB)		TRIP SELECTOR SWITCH		DC SUPPLY SUPERVISION RELAY		VOLTMETER
	VACUUM CONTACTOR (HV)		VOLTMETER		VOLUMETER		AMMETER
	THREE PHASE TRANSFORMER WITH OFF CIRCUIT TRIP CHANGER WITH 'S' STEPS		THERMAL OVERLOAD PROTECTION (49)		NEGATIVE PHASE SEQUENCE OVER CURRENT (44)		DEFINITE TIME EARTH FAULT ELEMENT (50+2)
	CURRENT TRANSFORMER 'S' INDICATES NUMBER		THERMISTOR RELAY (51)		IMT OVER CURRENT ELEMENT (51)		IMT EARTH FAULT ELEMENT (51N)
	MINIATURE CIRCUIT BREAKER (MCB) WITH POTENTIAL FREE CONTACT		INSTANTANEOUS OVER CURRENT ELEM (50)		INSTANTANEOUS EARTH FAULT ELEM (50N)		RESTRICTED EARTH FAULT PROTECTION (64R)
	DRAW-OUT TYPE CONTACTS		IMT EARTH FAULT ELEMENT (51S)		MOTOR PROTECTION RELAY (MPR)		UNDER VOLTAGE RELAY (27)
	CABLE GLAND		UNDER VOLTAGE RELAY WITH TIMER (27+2)		OVER VOLTAGE RELAY WITH TIMER (59+2)		SYNCHRONISM CHECK RELAY (2S)
	COMPOSITE MULTIFUNCTION METER		INSTANTANEOUS EARTH FAULT ELEMENT (50G)		LINE DIFFERENTIAL PROTECTION RELAY (87L)		MOTOR DIFFERENTIAL PROTECTION RELAY (87M)
	POTENTIAL TRANSFORMER (DRAWOUT TYPE)		TRANSFORMER DIFFERENTIAL PROTECTION RELAY (87T)		LOCAL CONTROL STATION WITH START, STOP PUSH BUTTONS		LOCAL CONTROL STATION WITH START, STOP PUSH BUTTON AND INDICATING LAMP
	BUSDUCT		MANUAL / INDEPENDENT SWITCH (AUTO/MANUAL SWITCH)		AUTO/MANUAL/INDEPENDENT SWITCH TRIP CIRCUIT SUPERVISION RELAY		TRIPPING RELAY
	'NO' CONTACT OF CONTACTOR		SERVO CONTROLLED VOLTAGE STABILIZER		ELECTRICAL INTERLOCK		MECHANICAL INTERLOCK
	ELECTRONIC OVERLOAD RELAY / DIGITAL MOTOR PROTECTION RELAY		BATTERY BANK		INVERTER		RECTIFIER
	SWITCH FUSE UNIT		STATIC SWITCH		HOUR METER / HOUR COUNTER (INTEGRATING TYPE)		RTD/BDT
	FUSE		ANNUNCIATOR (X - NO. OF WINDOWS Y - NO. OF AUDIBLE ALARM)		CURRENT TRANSDUCER (WITH OUTPUT GALVANIC ISOLATION)		TEMPERATURE SCANNER
	CORE BALANCE CURRENT TRANSFORMER						
	SURGE ARRESTER						
	VACUUM CONTACTOR (LV)						
	MOLDED CASE CIRCUIT BREAKER (MCB)						
	EARTH LEAKAGE CIRCUIT BREAKER						
	MINIATURE CIRCUIT BREAKER (MCB)						
	SPACE HEATER						
	THERMISTOR						
	THREE PHASE INDUCTION MOTOR						
	INDICATING LAMP - RED - GREEN - AMBER (AUTO TRIP) - BLUE (SPRING CHARGED) W1 - WHITE (TRIP CIRCUIT HEALTHY) W2 - WHITE (TEST) W3 - WHITE (SERVICE) W4 - WHITE (DC SUPPLY HEALTHY) R - RED - YELLOW - BLUE						
	BUCHOLZ RELAY/PROTECTIVE DEVICE (6-16 SECOND)						
	OIL TEMPERATURE INDICATOR						
	PRESSURE RELIEF VALVE						
	WINDING TEMPERATURE INDICATOR						
	MAGNETIC OIL GAUGE						
	LOAD BREAK SWITCH						

NOTES

- DATA MARKED *** SHALL BE DECIDED BY LSTK CONTRACTOR. THE RATING OF COMPONENTS IN INDIVIDUAL FEEDERS SHALL BE DECIDED BY SWITCHGEAR VENDOR BASED ON FEEDER LIST PROVIDED BY LSTK CONTRACTOR.
- ONLY MAJOR RELAYS HAVE BEEN INDICATED IN THE SLD. ANY OTHER COMPONENTS LIKE AUXILIARY RELAYS, TIMERS, SWITCHES ETC. AS REQUIRED WHILE DEVELOPING THE DETAILED SCHEMATIC FOR OPERATION SAFETY SHALL BE IN THE SWITCHGEAR VENDOR'S/LSTK CONTRACTOR SCOPE.
- 415V DC SETS ARE ENGAGED AT TWO LOCATIONS NER BUSTATIONS NO. US-503 & US-505.
- THE RATING OF 11kV/0.433kV TRANSFORMER SHALL BE RESTRICTED TO 2.5MVA ACCORDINGLY NO. OF TRANSFORMERS, PCC PANELS SHALL BE PROVIDED.
- THE PCC & MCC PANELS SHOWN ARE TYPICAL.
- NORMAL LIGHTING TRANSFORMER SHALL BE RATED FOR NORMAL LIGHTING LOAD, EMERGENCY LIGHTING TRANSFORMER SHALL BE RATED FOR EMERGENCY LIGHTING LOAD.
- FOR ALL ACTUATOR MOTORS IN PCC VACUUM CONTACTOR SHALL BE PROVIDED.
- OVERLOAD RELAY TYPE :
ELECTRONIC OVERLOAD RELAY : < 7.5kW
DIGITAL MOTOR PROTECTION RELAY WITH DISPLAY & FAULT RECORD : 7.5kW < MOTOR kW < 75kW
DIGITAL MOTOR PROTECTION RELAY WITH DISPLAY & FAULT RECORD : 55kW FOR ACTUATOR MOTORS
COMPREHENSIVE NUMERICAL MOTOR PROTECTION RELAY WITH DISPLAY & FAULT RECORD : 7.5kW
COMPREHENSIVE NUMERICAL MOTOR PROTECTION RELAY : < 55kW FOR ACTUATOR MOTORS
- 500 SHALL BE PROVIDED FOR NON-MOTORING LOADS (e.g. PROCESS HEATER LOAD) RATED ABOVE 500 kVA SHALL NOT BE PROVIDED FOR POWER FEEDERS (e.g. VFD, HVAC, UPS, BATTERY CHARGER).
- CLASS PS OF PARAMETERS SHALL BE PROVIDED DURING DETAIL ENGINEERING.
- SPACE FOR DIFFERENTIAL RELAY (FREE ISSUE TO LSTK CONTRACTOR) SHALL BE CONSIDERED IN SWITCHGEAR PANEL BY SWITCHGEAR VENDOR/LSTK CONTRACTOR.
- DETAIL SLD SHOWN IS TYPICAL LSTK CONTRACTOR SHALL DEVELOP DETAIL SLD INCLUDING ALL SUBSTATION EQUIPMENTS BASED ON ACTUAL REQUIREMENT.
- TRANSFORMER SHALL BE MOUNTED IN THE OUTGOING MOTOR FEEDER IN 1.6KV SWITCHGEAR.
- TRANSFORMER SHALL BE MOUNTED IN A SEPARATE PANEL FOR 6.6KV SWITCHGEAR, WHICH SHALL BE INSTALLED IN SUBSTATION.
- TRANSFORMERS SHALL BE MOUNTED IN A SEPARATE PANEL FOR 415V SWITCHGEAR, WHICH SHALL BE INSTALLED IN SUBSTATION. ONE COMMON TRANSFORMER PANEL FOR ALL 415V SWITCHGEAR SHALL BE PROVIDED.

REFERENCE DRAWINGS

6695-ELT-G00-EC-0002	GENERAL ENGINEERING SPECIFICATION – ELECTRICAL
6695-ELT-G00-EC-0003	GUIDELINES FOR ELECTRICAL EQUIPMENT NUMBERING SYSTEM
6695-ELT-G00-EC-0004	DESIGN GUIDELINES FOR ELECTRICAL FACILITIES
6695-ELT-G00-FA-0001	KEY SINGLE LINE DIAGRAM



SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
(Symbol)	DISCONNECTOR	(Symbol)	AUXILIARY RELAY
(Symbol)	MOTORIZED DRAW-OUT TYPE CIRCUIT BREAKER	(Symbol)	ANTI PUMPING RELAY
(Symbol)	VACUUM CONTACTOR (HV)	(Symbol)	TRIP-NEUTRAL-CLOSE SWITCH
(Symbol)	THREE PHASE TRANSFORMER WITH OFF CIRCUIT TAP CHANGER WITH 'S' STEPS	(Symbol)	TRIP SELECTOR SWITCH
(Symbol)	CURRENT TRANSFORMER 3 INDICATES NUMBER	(Symbol)	DC SUPPLY SUPERVISION RELAY
(Symbol)	MINIATURE CIRCUIT BREAKER (MCCB) WITH POTENTIAL FREE CONTACT	(Symbol)	VOLTMETER
(Symbol)	DRAW-OUT TYPE CONTACTS	(Symbol)	VOLTMETER SELECTOR SWITCH
(Symbol)	CABLE GLAND	(Symbol)	AMMETER
(Symbol)	COMPOSITE MULTIFUNCTION METER	(Symbol)	AMMETER SELECTOR SWITCH
(Symbol)	POTENTIAL TRANSFORMER (DRAWOUT TYPE)	(Symbol)	LOCKED ROTOR DETECTION RELAY (99)
(Symbol)	BUSDUCT	(Symbol)	THERMAL OVERLOAD PROTECTION (49)
(Symbol)	'NO' CONTACT OF CONTACTOR	(Symbol)	NEGATIVE PHASE SEQUENCE OVER CURRENT (46)
(Symbol)	FUSE	(Symbol)	DEFINITE TIME EARTH FAULT ELEMENT (50H+2)
(Symbol)	CORE BALANCE CURRENT TRANSFORMER	(Symbol)	THERMISTOR RELAY
(Symbol)	SURGE ARRESTER	(Symbol)	IMT OVER CURRENT ELEMENT (51)
(Symbol)	VACUUM CONTACTOR (LV)	(Symbol)	IMT EARTH FAULT ELEMENT (51N)
(Symbol)	SPACE HEATER	(Symbol)	INSTANTANEOUS OVER CURRENT ELEMENT (50N)
(Symbol)	THERMISTOR	(Symbol)	RESTRICTED EARTH FAULT PROTECTION (50)
(Symbol)	INDICATING LAMP	(Symbol)	IMT EARTH FAULT ELEMENT (51G)
(Symbol)	BUCHHOLZ RELAY/PROTECTIVE DEVICE (OF SECOND CHARGE)	(Symbol)	MOTOR PROTECTION RELAY (MPR)
(Symbol)	TEMPERATURE INDICATOR	(Symbol)	UNDER VOLTAGE RELAY (27)
(Symbol)	PRESSURE RELIEF VALVE	(Symbol)	UNDER VOLTAGE RELAY WITH TIMER (27+2)
(Symbol)	WINDING TEMPERATURE INDICATOR	(Symbol)	OVER VOLTAGE RELAY WITH TIMER (28+2)
(Symbol)	MAGNETIC OIL GAUGE	(Symbol)	ELECTRONIC OVERLOAD RELAY / DIGITAL MOTOR PROTECTION RELAY
(Symbol)	LOAD BREAK SWITCH	(Symbol)	SWITCH FUSE UNIT
(Symbol)		(Symbol)	FUSE
(Symbol)		(Symbol)	CORE BALANCE CURRENT TRANSFORMER
(Symbol)		(Symbol)	SURGE ARRESTER
(Symbol)		(Symbol)	VACUUM CONTACTOR (LV)
(Symbol)		(Symbol)	SPACE HEATER
(Symbol)		(Symbol)	THERMISTOR
(Symbol)		(Symbol)	INDICATING LAMP
(Symbol)		(Symbol)	BUCHHOLZ RELAY/PROTECTIVE DEVICE (OF SECOND CHARGE)
(Symbol)		(Symbol)	TEMPERATURE INDICATOR
(Symbol)		(Symbol)	PRESSURE RELIEF VALVE
(Symbol)		(Symbol)	WINDING TEMPERATURE INDICATOR
(Symbol)		(Symbol)	MAGNETIC OIL GAUGE
(Symbol)		(Symbol)	LOAD BREAK SWITCH

NOTES

- DATA MARKED: ** SHALL BE DECIDED BY LSTK CONTRACTOR. THE RATING OF COMPONENTS IN INDIVIDUAL FEEDERS SHALL BE DECIDED BY SWITCHGEAR VENDOR BASED ON FEEDER LIST PROVIDED BY LSTK CONTRACTOR.
- ONLY MAJOR RELAYS HAVE BEEN INDICATED IN THE SLD. ANY OTHER COMPONENTS LIKE AUXILIARY RELAYS, THERMISTORS, SWITCHES ETC. AS REQUIRED WHILE DEVELOPING THE DETAILED SCHEMATIC FOR SAFE OPERATION SHALL BE IN THE SWITCHGEAR VENDOR'S / LSTK CONTRACTOR'S SCOPE.
- 415V DC SETS ARE ENGAGED AT TWO LOCATIONS NER SUBSTATIONS NO. US-503 & US-505. THE RATING OF 11kV/0.433kV TRANSFORMER SHALL BE RESTRICTED TO 2.5MVA. ACCORDINGLY NO. OF TRANSFORMERS, PCC PANELS SHALL BE PROVIDED.
- THE PCC & MCC PANELS SHOWN ARE TYPICAL.
- NORMAL LIGHTING TRANSFORMER SHALL BE RATED FOR NORMAL LIGHTING LOAD, EMERGENCY LIGHTING TRANSFORMER SHALL BE RATED FOR ONLY EMERGENCY LIGHTING LOAD.
- FOR ALL AGITATOR MOTORS IN PCC VACUUM CONTACTOR SHALL BE PROVIDED.
- OVERLOAD RELAY TYPE :
ELECTRONIC OVERLOAD RELAY : < 7.5kW
DIGITAL MOTOR PROTECTION RELAY WITH DISPLAY & FAULT RECORD : 7.5kW < MOTOR kW < 75kW
DIGITAL MOTOR PROTECTION RELAY WITH DISPLAY & FAULT RECORD : 35kW FOR AGITATOR MOTORS
COMPREHENSIVE NUMERICAL MOTOR PROTECTION RELAY : MOTOR > 75kW
COMPREHENSIVE NUMERICAL MOTOR PROTECTION RELAY : > 55kW FOR AGITATOR MOTORS
- 500 shall be provided for non-motoring loads (e.g. PROCESS HEATER LOAD) RATED ABOVE 500kW. SDC SHALL NOT BE PROVIDED FOR POWER FEEDERS (e.g. VFD, PFC, HVAC, UPS, BATTERY CHARGERS) ETC.
- CLASS PS CT PARAMETERS SHALL BE PROVIDED DURING DETAIL ENGINEERING.
- SPACE FOR LINE DIFFERENTIAL RELAY (FREE ISSUE TO LSTK CONTRACTOR) SHALL BE CONSIDERED IN SWITCHGEAR PANEL. BY SWITCHGEAR VENDOR/LSTK CONTRACTOR.
- DETAIL SLD SHOWS IS TYPICAL. LSTK CONTRACTOR SHALL DEVELOP DETAILED SLD INCLUDING ALL SUBSTATION EQUIPMENTS BASED ON ACTUAL REQUIREMENT.
- TRANSFORMER SHALL BE MOUNTED IN THE OUTGOING MOTOR FEEDER IN 11kV SWITCHGEAR.
- TRANSFORMER SHALL BE MOUNTED IN A SEPARATE PANEL FOR 6.6kV SWITCHGEAR, WHICH SHALL BE INSTALLED IN SUBSTATION.
- TRANSFORMERS SHALL BE MOUNTED IN A SEPARATE PANEL FOR 415V SWITCHGEAR, WHICH SHALL BE INSTALLED IN SUBSTATION. ONE COMMON TRANSFORMER PANEL FOR ALL 415V SWITCHGEAR SHALL BE PROVIDED.

OPERATING PHILOSOPHY (MCC)

- NORMALLY I/C-1 AND I/C-2 SHALL BE KEPT IN CLOSED CONDITION AND B/C SHALL BE KEPT IN OPEN CONDITION.
- MANUAL CHANGEOVER BETWEEN I/C-1 & I/C-2 SHALL BE POSSIBLE BY MOMENTARY PARALLELING OF I/C-1 & I/C-2 WITH MANUAL / INDEPENDENT SWITCH ON B/C IN MANUAL MODE.
- WHEN MANUAL / INDEPENDENT SWITCH IS IN MANUAL MODE, TWO OUT OF THREE (I/C-1, I/C-2 & B/C) BREAKERS CAN BE CLOSED.

OPERATING PHILOSOPHY (MCCB)

- NORMALLY I/C-1 AND I/C-2 SHALL BE KEPT IN CLOSED CONDITION AND B/C SHALL BE KEPT IN OPEN CONDITION.
- IF ANY PROBLEM IN I/C-1 OR I/C-2, TR-34XX OR TR-34XX THEN BUS COUPLER SHALL BE CLOSED AFTER SWITCHING OFF I/C-1 OR I/C-2.
- MECHANICAL INTERLOCK IS PROVIDED BETWEEN I/C-1, I/C-2 & B/C.

REFERENCE DRAWINGS

6695-ELT-G00-EC-0002	GENERAL ENGINEERING SPECIFICATION - ELECTRICAL
6695-ELT-G00-EC-0003	GUIDELINES FOR ELECTRICAL EQUIPMENT NER SYSTEM
6695-ELT-G00-EC-0004	DESIGN GUIDELINES FOR ELECTRICAL FACILITIES
6695-ELT-G00-FA-0001	KEY SINGLE LINE DIAGRAM

Category Codes

Category Codes	1 for Approved	2 for Review / Comments	3 for Information / as Marked	4 for Engineering	5 for Enquiry	6 for Order Placement	7 Final & Approved	8 Released for Construction
----------------	----------------	-------------------------	-------------------------------	-------------------	---------------	-----------------------	--------------------	-----------------------------

Contract No. 66-6695 **Document ID** 6695-ELT-G00-FA-0003 **Part** 02

Store Location: Server/Share 66-6695-Add/Ascd

Store Location: Folder \\User\Org\Electrical\Single_Line_Diagram

Store Name: 6695-ELT-G00-FA-0003_S2_R1

Pro. Unit Con. Unit TON **Group** Order No. **Type of Document** Sheet 2 / 2

thysenkruupp

1.0 MTPA ALUMINA REFINERY STREAM-5 DAMANJODI, ODISHA

REVISIONS

Rev.	Date	Name	Description	Acc.	Scale	Cat. Code	Acc. Code	Status
02	22.03.18	RDK	POW	22.03.18	MSD	22.03.18	RPM/SLP	
01	19.01.18	RDK	BTk	19.01.18	MSD	19.01.18	RPM	
00	02.11.17	RDK	BTk	02.11.17	MSD	02.11.17	RPM/SLP	

Drawn 02.11.17 RDK **Prepared** 02.11.17 BTk **Checked** 02.11.17 MSD **Approved** 02.11.17 RPM/SLP

ISSUED FOR ENGINEERING

TELE COMMUNICATION, SCADA, FA, VFD'S TRANSFORMER PANEL AND OTHER CRITICAL LOADS

TYPICAL DETAIL SINGLE LINE DIAGRAM

ISO 9001